

# FIRE SUPPRESSION RATING SCHEDULE

---

## Appendix B

**TABLE 542B ADDITIONAL EQUIPMENT FOR A LADDER COMPANY**

<b>Equipment</b>	<b>Needed for Max Credit</b>
Ladder:	
16' or longer roof	1
35' or longer extension	1
Elevated stream device*	1
Large spray nozzle (1,000 gpm)	1
Aerial ladder/elevating platform*	1
Annual tests (aerial/platform, see Table 542C)	1

---

\*Of sufficient height to reach the roof of any building, or 100 feet, whichever is less. The credit shall be prorated if existing equipment has insufficient reach.

---

**TABLE 542C AERIAL LADDER/ELEVATING PLATFORM TEST PROGRAM**

<b>Average Interval between 3 Most Recent Tests</b>	<b>Maximum Points Credit</b>
1 year	50
2 years	37
3 years	25
4 years	12
5 years or more	0

Aerial Ladder/Elevating Platform Test Program shall be in accordance with the general criteria of NFPA 1911, *Standard for the Inspection, Maintenance, Testing, and Retirement of In-Service Automotive Fire Apparatus*.

Note: If partial records of testing exist, reduce the credit for testing in Section 542C by 25%; and if no records of testing exist, reduce the credit in Section 542C by 100%